



BANGALORE WATER SUPPLY AND SEWERAGE BOARD

DEMAND NOTE FOR NO OBJECTION CERTIFICATE

To

M/s KEYA Homes Pvt ltd
No. 17 Regent Court, Ground Floor, 80 ft road
Koramangala 4th block
Bangalore-560034

Sir,

Sub: Issue of No Objection Certificate for the proposed Residential Building at SY NO. 29/6, 30/2A & 30/2B OF KASAVANAHALLI VILLAGE SARJAPURA ROAD,, VARTHUR HOBLI, BANGALORE EAST TALUK, , BANGALORE, 560035 in favour of M/s KEYA Homes Pvt ltd

Ref: 1) Application Number: BWSSB-NOC-2024-9-93-092001004641
2) Date of Application: 2024-09-20
3) Demand Note Generation Date: 2024-10-03

With reference to the above, you are requested to make the following payments for issue of "No Objection Certificate" from BWSSB for the above said proposed project Residential Building at SY NO. 29/6, 30/2A & 30/2B OF KASAVANAHALLI VILLAGE SARJAPURA ROAD,, VARTHUR HOBLI, BANGALORE EAST TALUK, , BANGALORE, 560035

The Proposed project is for Residential Building consists of Tower-A, B, C and D GF + 24 Upper Floor + Terrace Floor and Common Bf for having 799 flats with the total Builtup area 164359.39 Smt and the Site Area is 33892.47 Smt. The premises comes under 110 Villages area

1. NOC Fees

Sl. No.	Proposed Building (Built Up Area in Smt)	Rate (in Rs.per Smt) / Minimum Rs.1,50,000/-	Amount (in Rs.)
1	164359.39	Rs.25/-	Rs.41,08,985/-
Total			Rs.41,08,985/-

2. Advance Probable Prorata charges

Sl. No.	Proposed Building	Built Up Area (Smt)	Amount (in Rs.)
1	Advance Probable Prorata Charges @ 15% of Rs.400/- : Residential Portion	164359.39	Rs.98,61,564/-
Total			Rs.98,61,564/-

3. GBWASP / BCC Charges

Sl. No.	Proposed Building	No of Flats/Built up Area in Sft	Rate	Amount
1	Upto 600 SqFt	72	Rs.5,000/-	Rs.3,60,000/-
2	601 SqFt to 1200 SqFt	144	Rs.10,000/-	Rs.14,40,000/-
3	1201 sft upto 2400 SqFt	583	Rs.20,000/-	Rs.1,16,60,000/-
Total				Rs.1,34,60,000/-

4. Treated Water Charges for Construction

Sl. No.	Total Builtup Area Smt	Rate (in Rs. per Smt)	Amount (in Rs.)
1	164359.39	Rs.10/-	Rs.16,43,594/-
Total			Rs.16,43,594/-

The **Grand Total Charges** towards this Demand Note for No Objection Certificate is **Rs.2,90,74,143/- (Rupees Two Crore Ninety Lakh Seventy-Four Thousand One Hundred and Forty-Three Only)**

Further No Objection Certificate will be issued after the above said charges are remitted to BWSSB.

Demand note issued is subject to the following conditions.

1. This demand notice stands valid for a period of six months only from the date of issue. If payment is not made till such time the fresh application for issue of NOC should be submitted from your end owing to automatic cancellation of this demand notice.
2. NOC issued by the Board will be valid for three (3) years only from the date of issue of NOC. NOC issued will be revoked if any dispute arises at any stage.
3. The NOC demand note issued is solely on the information provided by applicant while submitting the NOC application online without inspection of site by BWSSB. If any discrepancies/ malafide information/disputes are found in the submitted application BWSSB is not responsible and the NOC demand note issued is not valid/and it is Null & Void.
4. The NOC demand note issued shall not be considered as the substitution for any statutory rules governing the state and cannot set aside the competent authorities to enforce/impose the restrictions with respect to rules under town/country planning, Buffer zones of lakes and drains etc.
5. The applicant/builder/owner should abide to the rules & regulations of BWSSB issued time to time.
6. This demand note is issued subject to condition that applicant/builder/owner should not discharge the treated sewage into BWSSB sewer network and should not discharge the untreated sewage into storm water drain and abide to the notification regarding Environment Impact Assessment issued from department of Forest, Ecology and environment from time to time and the directions issued in the NGT orders.
7. Water supply to your premises can be assured subject to availability.
8. The cost of additional strengthening work or change in tapping / disposal point has to be borne by the builder / owner, at the time of sanctioning the water supply & UGD connection as per the prevailing rules and regulation
9. If the above area falls under Thippagondanahalli Catchment area this NOC will automatically be treated as cancelled
10. This NOC is only to provide the BWSSB services to the proposed building. The necessary conversions for usage of land and statutory approval shall be obtained from concerned Departments
11. As per BWSSB Act Section 72(A) and relevant regulations, Rain Water Harvesting is mandatory, the applicant has to make necessary provisions for harvesting rain water. While designing the roof based RWH structure the capacity of a storage structure or for artificial recharge structures to groundwater, a provision at the rate of 60 liters or more capacity per Sq.mtr of the roof area shall be adopted and While designing the Land based RWH structure the capacity of a storage structure or for artificial recharge structures to groundwater, a provision at the rate of 30 liters or more capacity per Sq.mtr of the Land surface shall be adopted. Letting out rain water into the Board sewerline is strictly prohibited as per Sec 72. The builder/developer should not provide sanitary points in cellar or Basement floor

Yours faithfully,

Chief Engineer(East)

BWSSB

This is a system generated Demand Note and it does not require any signature