

The domestic sewage shall conform to the following standards as per **Annexure - 1**.

Sl. No	Annexure -1	
	Parameter	Permissible Limit
1	pH	6.5 - 9.0
2	BOD (mg/l)	Not more than 10
3	COD (mg/l)	Not more than 50
4	TSS (mg/l)	Not more than 20
5	NH4-N (mg/l)	Not more than 5
6	N-Total (mg/l)	Not more than 10
7	Fecal Coliform (MPN/100 ml)	Less than 100



**SENIOR ENVIRONMENTAL OFFICER
BNG - EAST ZONAL OFFICE**

