



## BANGALORE WATER SUPPLY AND SEWERAGE BOARD

### NO OBJECTION CERTIFICATE (NOC)

To

M/s CARDINAL ENERGY AND INFRASTRUCTURE Pvt Ltd  
No 36 Tumkur Service Main road,  
Peenya Industrial Area,  
Behind Goraguntepalya Metro Station,  
Bangalore-560022

Sir,

Sub: Issue of No Objection Certificate for the proposed Residential Building at Survey No 11, 1st Stage, 1st Phase, East End Road,,Thilaknagar, Gurappana Palya, Next to Food Corporation of India, Bangalore, 560041 in favour of M/s CARDINAL ENERGY AND INFRASTRUCTURE Pvt Ltd

- Ref: 1) Application Number: BWSSB-NOC-2024-7-7454-071610155779  
2) Date of Application: 2024-07-16  
3) Demand Note Generation Date: 2024-08-05  
4) NOC Generation Date: 2024-04-20

\*\*\*\*\*

The "No Objection Certificate" from BWSSB for providing water supply and underground drainage facilities is issued subject to the following conditions:

1. The NOC (no objection certificate) document issued shall not be considered as the substitution for any statutory rules governing the state and can't set aside the competent authorities to enforce / impose the restrictions with respect to rules under town/country planning, Buffer zones of lakes and drains etc.
2. The NOC issued is solely on the information provided by applicant while submitting the NOC application online with inspection of site by BWSSB. If any discrepancies/ malafide information are found in the submitted application BWSSB is not responsible and the NOC issued is not valid/and it is Null & Void
3. The builder/ developers should abide the "Acts, Rules and Regulations of BWSSB" issued time to time.
4. The builder/ developer has to pay the necessary prorata and other charges towards the building as specified by the Board prevailing at the time of sanction of water supply and sanitary connection.
5. Builder/ developer has to bear the cost of pipeline estimate for both water supply and U.G.D lines, if there is no network near by the premises or requires up gradation of existing system at the time of sanctioning of connection.
6. NOC issued should be produced at the time of availing connection along with plan.
7. The difference in amount collected towards NOC and GBWASP charges, between the proposed area & actual construction area shall be paid at the time of seeking water supply and sanitary connections.
8. Under any circumstances, the NOC charges collected will not be refunded.
9. The treated water shall be used for construction purposes.
10. As per BWSSB Act Section 72(A) and relevant regulations, Rain Water Harvesting is mandatory, the applicant has to make necessary provisions for harvesting rain water. Letting out rain water into the Board sewer line is strictly prohibited as per Sec 72. The builder/developer should not provide sanitary points in cellar or Basement floor.
11. As per Bangalore Sewerage regulation 4(A) Adoption of STP & dual piping system is mandatory for the below mentioned buildings
  - i) Residential buildings consisting of 120 and above apartments or generating sewage of 80 KLD above whichever is lower; or
  - ii) Commercial building measuring 5,000 sqm and above; or generating sewage of 35 KLD above whichever is lower; or
  - iii) Buildings of educational institutions measuring 5,000 sqmtrs and above or generating sewage of 35 KLD or above shall install STPAccordingly the owner / developer has to set up suitable sewage treatment plant as per KSPCB and NGT orders for treating the waste water generated in their premises to achieve the standards. Consent for operation of STP from KSPCB is mandatory.
12. This NOC is issued subject to condition that applicant/builder/owner should not discharge the treated sewage into BWSSB sewer network and should not discharge the untreated sewage into storm water drain and the applicant is solely responsible for any environmental pollution due to the same.
13. The owner / developer is abide to the notification regarding Environment Impact Assessment issued from department of Forest, Ecology and environment from time to time and the directions issued in the NGT orders.
14. The orders of the National Green Tribunal (NGT) original application No.222/2014. Principal Bench New Delhi. Forward Foundation and others vs. State of Karnataka and others should be followed stringently

For CARDINAL ENERGY & INFRASTRUCTURE PVT. LTD.

AUTHORISED SIGNATORY

15. Owner / Developer has to provide internal meters and Automatic water level control sytem as per the BWSSB regulation 43(A)-Obligation to provide internal meters and 43(B) - Obligation to provide Automatic water level control sytem
16. The building including basement should be above the High Flood level of adjacent valleys, storm water drain, low lying area.
17. STP operation log book should be maintained duly incorporating other details such as test results etc.,
18. Chartered energy meter should be installed for STP duly obtaining permission from BESCOM.
19. Authorized personnel from Board & other Government Departments are empowered to inspect the STP without prior intimation & randomly at any time
20. For NOC to layouts, the applicant has to ear-mark the land if required for construction of GLR, OHT, sump tank, pump house service station etc., and land should be handed over to BWSSB "free of cost".
21. If any BWSSB lines are passing through the premises, the necessary shifting charges has to be borne by the builder/ developers. Further, set back has to be provided as directed by Board for safety of the pipelines.
22. BWSSB reserves the right to sanction or reject the water supply or UGD Connections without assigning any reasons. The quantity and pressure of water will not be assured.
23. Land acquired or notified for BWSSB infrastructure development or earmarked for BWSSB works should not be encroached or any structures constructed. If violated, penal action will be initiated.
24. Necessary approval should be obtained from BWSSB/Karnataka Ground Water Authority before sinking Borewells in the premises.

**The Proposed project is for Residential Building consists of BF + Stilt Floor + 13 Upper Floor + Terrace Floor with Club House for having 24 units with the total Builtup area 10176.67 Smt and the Site Area is 2636.15 Smt. The premises comes under Core Area.**

The Developer has paid an amount of Rs. 2,54,417/- towards No Objection Certificate charges.

The Developer has paid an amount of Rs. 6,43,743/- towards Advance Probable Prorata charges

The Developer has paid an amount of Rs. 1,01,767/- towards Treated Water charges

The total charges of Rs. 9,99,927/- (Rupees Nine Lakh Ninety-Nine Thousand Nine Hundred and Twenty-Seven Only) has been paid via Demand Draft on 2024-08-08 drawn on State bank of India Fort Market Mumbai via Reference Number 44342 13.08.2024

**Note:**

1. Water supply to your premises can be assured subject to availability.
2. The current NOC shall be only for the plan submitted for the above property & the applicant shall obtain the revised NOC from BWSSB for any modification in the plan.
3. The cost of additional strengthening work or change in tapping / disposal point has to be borne by the builder / owner, at the time of sanctioning the water supply & UGD connection as per the prevailing rules and regulation.
4. NOC issued by the Board will be valid for three (3) years only from the date of issue of NOC. NOC issued will be revoked if any dispute arises at any stage
5. If the above area falls under Thippagondanahalli Catchment area this NOC will automatically be treated as cancelled

For CARDINAL ENERGY & INFRASTRUCTURE PVT. LTD.

  
AUTHORISED SIGNATORY

Yours faithfully

Signature valid

  
Signed By: S V VENKATESH  
Signing Time: 20-08-2024 15:09:27  
Signing Reason: NOC Approval  
Location: Bangalore Water Supply and Sewerage Board,  
Bengaluru

Chief Engineer(South)

BWSSB



भारतीय स्टेट बैंक  
State Bank of India

जारी करने वाली शाखा  
Issuing Branch: FORT MARKET (MUMBAI)  
कोड नं./CODE No. 05347  
Tel No. 022-69244348

मांगद्राफ्ट  
DEMAND DRAFT

Key QEH800  
Sr. No. 107066

0 8 1 0 8 2 0 2  
D D M M Y Y

9  
8  
7  
6  
5  
4  
3  
2  
1

मांग करने वाला THE CHAIRMAN B'WSS&S BANGLORE

रुपये RUPEES AND PAY

Nine Lakh Ninety Nine Thousand Nine Hundred and Twenty Seven Only ₹

अदा करें

999917 00

IOI 000540148901  
Name of Applicant

Key QEH800 S. No. 107066  
CARDINAL ENERGY & INFRASTRUCTU

AMOUNT BELOW 999928(0/6)

मूल्य प्राप्त / VALUE RECEIVED

प्राधिकृत हस्ताक्षरकर्ता  
AUTHORISED SIGNATORY

शाखा प्रबंधक  
BRANCH MANAGER

कम्प्यूटर द्वारा मुद्रित होने पर ही वैध  
VALID ONLY IF COMPUTER PRINTED

केवल 3 महीने के लिए वैध  
VALID FOR 3 MONTHS ONLY

भारतीय स्टेट बैंक  
STATE BANK OF INDIA  
हस्ताक्षर शाखा / DRAWING BRANCH BANGALORE  
कोड नं./CODE No. 00813

SUNIL LAXMAN SARAF  
INSTRUMENTS FOR ₹ 1,50,000/- एवं अधिक के लिखत दो अधिकारियों द्वारा हस्ताक्षरित होने पर ही वैध है।  
INSTRUMENTS FOR ₹ 1,50,000/- & ABOVE ARE NOT VALID UNLESS SIGNED BY TWO OFFICERS

⑈ 14996 1⑈ 000002000⑈ 000540⑈ 16

*Bank*  
*[Signature]*  
*12/8/2011*